

OFFICE OF DY. CHIEF FIRE OFFICER (REGIONAL)
MUMBAI FIRE BRIGADE
Borivali Regional Command Centre
Link Road X Gorai Road Junction
Borivali (West), Mumbai - 400 091

MUMBAI MUNICIPAL CORPORATION
MUMBAI FIRE BRIGADE

Office of the Deputy Chief Fire Officer (R-IV), Borivali Regional Command Centre
Link Road X Gorai Junction, Borivali (West), Mumbai- 400103. Tel. No. 2868012

No.:- FB/R4/Gen/442
Date:- 25/07/2025

C.F.O.,


- Sub:-** Compliance of the fire safety measures at Vidya Mandir School of M/s Vidya Prasarak Mandal at Chhatrapati Shivaji Marg, Dahisar (East), Mumbai- 400068.
- Ref:-** 1. M/s Vidya Prasarak Mandal, Dahisar letter u/n VPM/2025/47 dated 02.07.2025.
2. M.F.B. No. R-IV/Gen/442 dated 02.07.2025.

Sir,

Please refer to the letter received from M/s Vidya Prasarak Mandal, Dahisar for Vidya Mandir School at Chhatrapati Shivaji Marg, Dahisar (East), Mumbai- 400068 requesting compliance of the fire safety measures of this department requirements in accordance with MFP&LSM Act 2006. The party has submitted:

- 1) **Form 'B'** Certificate u/n MC/2025-26/JUL 113 dated 03.07.2025 for the period January to June 2025 as per Maharashtra Fire Prevention & Life Safety Measures Act 2006 from Govt. Approved Licensed Agency, M/s Mani Consultancy, having License No. MFS-LA/D-513/P-126 for the maintenance and good working condition of the existing fixed fire-fighting installations & fire-fighting equipment provided in the school building.
- 2) **Electrical Audit Certificate dated 27.05.2025** from M/s. Saiba Enterprises (Lic. No. 22257).
- 3) **Structural Stability Certificate from M/s. RDB Alliance LLP**, Structural Engineer dated 20.07.2025. (STR No. 0840005856).
- 4) Fire N.O.C. for occupation letter by this department is issued u/n CHE/A-3578/BP(WS)/AR-CFO/1/New dated 18.03.2024 for the stipulated fire protection & fire-fighting requirements.

The premise was inspected by the Senior Officer of this department on 03.07.2025. During the inspection, it is found that the School Management has complied & maintained the Fire Safety Measures stipulated by this department. As far as this department is concerned, this compliance report is issued from the fire-fighting installation point of view to M/s Vidya Prasarak Mandal, Dahisar for Vidya Mandir School at Chhatrapati Shivaji Marg, Dahisar (East), Mumbai- 400068 for CBSE affiliation purpose for the year 2026-27 without prejudice to legal matters pending in the court of law, if any.


Dy. Chief. Fire Officer (R-IV)
Mumbai Fire Brigade

✓ Ce: M/s Vidya Prasarak Mandal, Dahisar.

MANI CONSULTANCY

Liasoning, Supply, Installation & Consultation of Fire Fighting Systems
Govt. of Maharashtra Approved Licensed Fire Agency

Off. Address :- A/1005, Dhaivat Bldg, Kalpa Nagri, Vaishali Nagar, Mulund West, Mumbai- 400080.
Contact No. **9869201825**. Email:- chintanshah@maniconsultancy.co / project@maniconsultancy.co

Ref. No.: MC/2025-26/JUL 113

Date: 03/07/2025

FORM 'B'
CERTIFICATE
[Section 3(3) and Rule 4 (1)]

Certified that we have carried out inspection of the Fire Prevention and Life Safety Measures installed in the following building or premises.

Description and Location of Building or Premises in

M/S. VIDYA PRASARAK MANDAL
Opp. DSF Ground, Dahisar East, Mumbai-400068.

Type of Work: **1) Fire Alarm System**
2) Fire Extinguisher

We further certify that these installation in the above mentioned building are in good repair and efficient conditions during the period **JANUARY 2025 TO JUNE 2025** as required under the provisions of the Maharashtra Fire provisions and Life Safety Measures Act, 2006 (Mah.III of 2007). The details of the inspection of installations carried out by us are mentioned in the report appended herewith.

Place: Mumbai
Date: 03/07/2025
License No.: **MFS / LA / D-513 / P-126**

M/S. MANI CONSULTANCY

DEEPIK Digitally signed
by DEEPIKA SHAH
A SHAH Date: 2025.07.03
17:49:57 +05'30'

Authorized Signatory

MANI CONSULTANCY

Liasoning, Supply, Installation & Consultation of Fire Fighting Systems
Govt. of Maharashtra Approved Licensed Fire Agency

Off. Address :- A/1005, Dhaivat Bldg, Kalpa Nagri, Vaishali Nagar, Mulund West, Mumbai- 400080.
Contact No. **9869201825**. Email:- chintanshah@maniconsultancy.co / project@maniconsultancy.co

Ref. No.: MC/2025-26/JUL 113

Date: 03/07/2025

ANNEXURE TO FORM 'B'

M/S. VIDYA PRASARAK MANDAL
Opp. DSF Ground, Dahisar East, Mumbai-400068.

This is to certify that all the system installed is found in a good and working condition.

Sr. No.	LIST OF MATERIAL	Qty.	Remarks
1.	8 Zone Fire Alarm Control Panel	01 Nos.	OK
2.	Smoke Detector	40 Nos.	OK
3.	Manual Call Point	06 Nos.	OK
4.	Hooter	06 Nos.	OK
5.	ABC Type Fire Extinguisher 9 kg Capacity	10 Nos.	OK

Thanks & Warm Regards,
M/S. MANI CONSULTANCY

DEEPIK Digitally signed
by DEEPIKA
SHAH
A SHAH Date: 2025.07.03
17:50:30 +05'30'

Authorized Signatory



Govt. of Maharashtra
Directorate of Maharashtra Fire Service
Vidyanagri, Hans Bhugra Marg, Santacruz (East),
Mumbai – 400 098, Tel-022-26677555, Fax-022-26677666
www.mahafireservice.gov.in

FORM N
[(See section 9 (3) and rule 14]
License to act as a License Agency for the purpose of
Fire Prevention and Life Safety Measure

License No. MFS / LA / D- 513 / P-126

Date: 05.12.2024

License is hereby granted under the provisions of sub-section (3) of section 9 of the Maharashtra Fire Prevention and Life Safety Measure Act, 2006 (Mah. III of 2007) to **M/s. Mani Consultancy** having their registered office at **Wing B-1, 1103-1104, Silvino Projects – Senroofs, Goregaon, Mulund Link Rd, Mulund West, Mumbai 400080** and their contact details are Office Number: 9869201825 and Email ID: chintanshah@maniconsultancy.co with PAN registration No. AMRPB2957N and GST No. 27AMRPB2957N1ZF to act as a Licensed Agency for the purpose of the said Act for execution of the fire prevention and life safety measures in relation to

- 1. Detection and Fire Suppression System: Class D**
- 2. Passive System: Class D**

M/s. Mani Consultancy shall not issue Form A or Form B under sub-section (3) of section 3 regarding the compliance of the fire prevention and life safety measures or maintenance thereof in good repair and efficient condition, without there being actual such compliance or maintenance failing which license granted / renewed shall be suspended or cancelled as per sub section (4) of section 9 and shall be liable for penalty under section 36 of the Act.

Subject to the provision of sub section (4) of section 9 of the said Act and rule 14 of the Maharashtra Fire Prevention and Life Safety Measures Rules, 2009, the license will be valid for a period from **05.12.2024 to 04.12.2026**

Hatyal
Kiran
Asst Director

Digitally signed
by Hatyal Kiran
Date: 2024.12.11
09:15:44 +05'30'

DEEPIKA
SHAH

Digitally signed by
DEEPIKA SHAH
Date: 2024.12.09
12:33:55 +05'30'

SANTOSH
SHRIDHAR
WARICK

Digitally signed by
SANTOSH SHRIDHAR
WARICK
Date: 2024.12.11
11:14:37 +05'30'

(S S Warick)

Director
Maharashtra Fire Service

Digital Signature of Authorized Person to sign Form A or Form B

Note:

* in absence of digital sign of license holder (responsible to issue Form A or Form B) the license will be treated as invalid.

This license has been issued under the provisions in section 9 (5) and section 18 (2) and is valid in all Local Authorities as defined in section 2 (7) & Planning Authorities as defined in section 2(12) of the Maharashtra Fire Prevention and Life Safety Measures Act, 2006.

1. The licence shall be :-

- a) Non-transferable
- b) Valid for two year from the date of issue, unless suspended or cancelled earlier.
- c) Renewable, if so desired, before expiry of the licence.

2. Changes, if any. In respect of the –

- a) Partners, Directors or Members
- b) Address of the office of the License Agency

Shall be forthwith reported to the Directorate of Maharashtra Fire Service.

3. The Licensed Agency shall always keep the work executed or being executed, open for inspection by the Director, or any Fire Officer authorized by the Director.
4. The Licensed Agency shall issue a certificate in Form "A" to the client in respect of the works executed by them and shall issue a six monthly certificate in Form –"B", in every January and July after carrying out inspection of the Fire Prevention and Life Safety Measures work executed, being executed by them is in good repair and efficient conditions at all times.
5. Refer Circular issued by this Office vide No. MFS/51/2022/236, dated 15.02.2022

6. **M/s. Mani Consultancy (Proprietor) has paid amount of Rs. 5000/- (Rs. Five Thousand Only) vide UTR No. N32243409062613, dated 21.11.2024 towards registration fees.**



Govt. of Maharashtra
Directorate of Maharashtra Fire Service
Vidyanagri, Hans Bhugra Marg, Santacruz (East),
Mumbai – 400 098, Tel-022-26677555, Fax-022-26677666
www.mahafireservice.gov.in